

## [high pressure high temperature gate valve](#)

Product description:

Testing standard :API598

Flexible Wedge

Face to face according to ANSI B 16.10

RT (Radiographic Testing) for end weld parts

BW ends standard is ANSI B 16.25

Seat ring with stellite overlay and installed with seal weld.

Bolted bonnet or pressure seal bonnet are upon client request

Prolonged function and more compact valves characterized by light weight, small volume and less maintenance, specifically designed for the high temperature and the high pressure services encountered in nuclear and fossil

fuel power plants.